

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20192818  
Address: 4064 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Khanh Nguyen	Failed	Thursday, October 15, 2020

Corrective Action Required:

1	Misc	**CHECK PRODUCT APPLICATION TO THE EXTERIOR WALL REQUIRED TO BE FIRE-RATED AS REQUIRED PER APPROVED CMR. I OBSERVED 1ST LAYER APLIED (FLAME CONTROL COATING 149). PICTURES TAKEN AND EMAILED TO M. HARDING
---	------	--

**Comments:**