

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191872
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Construction Inspection		Partial	Friday, October 16, 2020

Informational:

1 Misc

John DiMauro 9/26/2020 11:00 AM - AFTER HOURS INSPECTION

The Redford crew is working on the water line 2 install. The crew has the line installed to approx 3+32. Photos are uploaded.

Informational:

2 Misc

John DiMauro 10/16/2020 8:11 AM

The Redford crew chlorinated the water lines for the project. I verified that there was at least 25 PPM of chlorine at the ends of the lines with the test strips provided.

Comments: