

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201372
Address: 4701 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Khanh Nguyen	Failed	Friday, October 16, 2020

Corrective Action Required:

1	Misc	-Drive the grounding rod into ground
---	------	--------------------------------------

****why the rod is still not driven into the ground? I would like to remind you that this is the 3RD failed inspection.**

Comments: