

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201668

Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082159 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Patrick Schonfeldt	Failed	Friday, October 16, 2020

Corrective Action Required:

1	Misc	- 1000 AMP DISCONNECT NOT INSTALLED AS PER PLANS, RESUBMIT REVISED PLAN WITH CHANGES BEFORE SCHEDULING REINSPECTION -TIGHTEN ALL LUGS, CONNECTIONS, BUSHINGS, AND JAMB NUTS IN METERS AND DISCONNECTS -EMT NOT RATED FOR OUTDOOR USE -CORRECT BONDING BUSHING -COLOR CODE NEUTRAL
---	------	---

Comments: