

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202580
Address: 1316 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Residential	Khanh Nguyen	Partial	Friday, October 16, 2020

Corrective Action Required:

1	Misc	GARAGE PORTAL BRACE WALL NAIL OK; HOWEVER, INSTALL STRAPS TO TIE DOWN THE LVL BEAM
---	------	--

Comments: