

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201750
Address: 232 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Friday, October 16, 2020

Corrective Action Required:

1	Misc	- INSTALL STORE FRONT GLASS - - LABEL SERVICE PANEL - - PROVIDE HAMMER ARRESTORS WASHING MACHINE - - PROVIDE 1" CLEARANCE AT B VENT - - COMPLETE ELECTRICAL THROUGHOUT - - LIST SUBJECT TO CHANGE NOT READY 10/16/20 -
---	------	---

Comments: