

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20200811	Date:	October 19, 2020
Project Title:	FIRESTONE	Applicant:	
Location:			
3521 SW MARKET ST, Unit:IR, LEES SUMMIT, MO		GOAL FIRE PROTECTION, LLC	
640823521 SW MARKET ST, LEES SUMMIT, MO 64082		8162 MONTICELLO TER	
Type of Work:		SHAWNEE, KS 66227	
Occupancy Group:	S-1		
Description:	NEW BUILDING FOR TIRE STORE	Primary:	(913) 441-3390
WITH 7 SERVICE BAYS			
Construction Type:	Type VB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test and a alarm/ water flow test.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**