

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201451
Address: 4405 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, October 20, 2020

Corrective Action Required:

1	Misc	-Ensure all top and bottom plate penetrations are fire blocked and sealed -Missing truss connector in garage -D5 hangers
---	------	---

HOUSE INSULATED WITHOUT APPROVAL - REMOVE INSULATION FROM ALL TOP AND BOTTOM PENETRATIONS THROUGHOUT TO ALLOW FOR INSPECTION

Comments: