

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201448
Address: 1524 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|---------------------------|
| All Rough Inspection - Residential | Patrick Schonfeldt | Failed | Tuesday, October 20, 2020 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Seal all top plate penetrations -EC#2 per plans -Anchor all columns to floor -Joist hanger at floor joist above basement stair landing, not bearing enough on top plate HOUSE INSULATED WITHOUT APPROVAL - REMOVE INSULATION COVER FROM ALL PLATE PENETRATIONS THROUGHOUT HOUSE TO ALLOW FOR INSPECTION |
|---|------|--|

Comments: