

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201699
Address: 1618 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Tuesday, October 20, 2020

Corrective Action Required:

1	Misc	-SILT FENCE REQUIRED AT FRONT OF LOT, MAINTAIN SILT FENCE -CLEAN MUD/GRAVEL IN STREET, MUD BUILDUP AT STORM INLET -REMOVE CONSTRUCTION DEBRIS ON TOP OF AND IN FRONT OF STORM INLET
---	------	---

Comments: