

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200943  
Address: 1606 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Patrick Schonfeldt	Failed	Tuesday, October 20, 2020

Corrective Action Required:

1	DCM6 ESC INSP DENIED STREET CLEAN UP	-MAINTAIN EROSION CONTROL ON LOT. SILT FENCE REQUIRED AT FRONT OF LOT -CLEAN MUD/GRAVEL IN STREET, CLEAN MUD/GRAVEL BUILDUP AT STORM INLETS
---	--	--

**Comments:**