

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201011
Address: 4016 SW MERITAGE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Tuesday, October 20, 2020

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	-MAINTAIN EROSION CONTROL ON LOT, SILT FENCE REQUIRED AT FRONT OF LOT -CLEAN MUD/GRAVEL IN STREET
---	---------------------------------------	--

Comments: