

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201729  
Address: 1863 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Partial	Thursday, October 22, 2020

Corrective Action Required:

1	Misc	-Have engineer address lvl beam with one ply break above office return air
		-Tempered glass window required at mid-stair landing

**\*\*OK TO ROCK PENDING APPROVAL FROM ENGINEER**

**Comments:**