CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182609

Address: 833 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Miscellaneous Inspection Robb Popp Partial Thursday, October 22,

2020

Corrective Action Required:

1 Miscellaneous -Signage throughout

Correction -Secure windows in stairwells

4th Floor

-Seal drywall patch in mechanical closet north

-Mechanical closet south-no access

-Fire extinguishers/ cabinets in hallway

-Cover plates in hallway

-Set escutcheon in hall by 406

411 seal joint in rock mechanical closet at line set, spark ring microwave,

escutcheon in kitchen

410 Cover plate in bedroom, seal joint in mechanical closet

409 patch hole in mechanical

408 place range on anti tip, hammer arrester at sink, spark ring at microwave

407 seal gaps and penetration in mechanical closet

406 adjust door, seal gap between wall and ceiling in mechanical

405 seal gaps in mechanical

404 adjust door, seal joint in mechanical closet

403 several workers cleaning, inaccessible

402 seal penetrations mechanical

401 still working-no access
400 missing escutcheon in dining, seal line set in mechanical

3rd Floor

-Missing cover plates in elevator equipment room

300 Seal gaps at middle and back line sets in mechanical closet

302 missing cover plate in bedroom 2

303 install missing deck railing

304 door doesn't close and latch properly, seal gaps at middle and back line sets

306 bad gfci at exterior

307 seal penetrations in mechanical closet

310 bath fan doesn't work

833 Donovan

301 ok

303 complete deck railing

305 ok

307 fire caulk ceiling mech room

309 ok

311 ok

10-22-20

2nd Floor

200 cover plate at mirror in bath

206 hammer arrestor at sink, no dishwasher/discharge line

207 hammer arrestor at sink

209 no dishwasher/ discharge line

211 no meter- not inspected

213 hammer arrestor at sink, no dishwasher/ discharge line

10/20/20

1st floor

Install Dishwashers, Install weatherstripping,

Provide two 3" screws in each exterior door hinge & strike plate

100 2" screws patio door, ADA hand held shower, land conductor above range in a box or fixture, dishwasher, cover plate master vanity

101 fixture above shower, cover plate above vanity, dishwasher, broken

102 3" screws patio door, dishwasher

103 dishwasher

window, cover

104 dishwasher, 3" screws patio door, bath exhaust fan

105 dishwasher

106 dishwasher, 3" screw patio door

107 dishwasher

108 ADA hand held shower, 3"'screws patio door,

Install dishwasher

109 dishwasher & hammer arrestor, deck rail,

111 dishwasher
110 cover plate bedrooms, hvac grills, 3" screws patio door, install
dishwasher, floor receptacle. ADA?
113 cover plate bedroom
Janitor closet extend water heater pan to floor sink, self closing door, fire
caulk tubs

Basement Floor not ready
Fire caulk h frames, complete electric
Handrail @ 42" ???
2nd floor not inspected

Comments: