

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182625

Address: 833 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Michael Harkins	Failed	Friday, October 23, 2020

Corrective Action Required:

1	Misc	- NAIL STUDS REAR CORNERS OF END UNITS EVERY 12" - - PROVIDE ANCHOR BOLT WITHIN 12" OF PLATE BREAK 3RD UNIT -
---	------	--

Comments: