

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200840
Address: 2914 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Friday, October 23, 2020

Corrective Action Required:

1	Misc	- sump pump discharge location, minimum 36" from foundation - - PROVIDE 6" WOOD SIDING TO SOD NORTH SIDE - - SUBMIT BACKFLOW CERTICATION LAWN IRRIGATION PERMIT PRRES20203261 -
---	------	--

OK for TCO EXPIRES 11/02/2020

Comments: