

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200993
Address: 3013 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Friday, October 23, 2020

Corrective Action Required:

1	Misc	- NO DECK PIER INSPECTION ON RECORD NOT NOTED ON 3RD PARTY INSPECTION - - PLANS CALL FOR DETAIL J 18 X 36 W/ (4) VERTICAL # 4 BARS -
---	------	---

OK for TCO EXPIRES 10/27/2020

Comments: