

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201235
Address: 2935 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Friday, October 23, 2020

Corrective Action Required:

1	Misc	-Complete final grade and sod - -Splash blocks at all downspout and sump pump discharge locations, minimum 36" distance from foundation -secure low volt data cable off of b vent flue at water heater in basement (1" CLEARANCE) - SUBMIT BACKFLOW CERTIFICATION LAWN IRRIGATION PERMIT PRRES20203273 - - PROVIDE 6" CLEARANCE WOOD SIDING TO SOD - - NO COVERED PATIO PIER INSPECTION ON RECORD -
---	------	--

Comments: