

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200127
Address: 2931 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Friday, October 23, 2020

Corrective Action Required:

1	Misc	- PROVIDE SUMP DISCHARGE 36" FROM FOUNDATION - - NO COVERED PATIO PIER INSPECTION ON RECORD - - SUBMIT BACKFLOW CERTIFICATION LAWN IRRIGATION PERMIT 20203178 - - - PROVIDE 6" CLEARANCE WOOD SIDING TO SOD - OK for TCO EXPIRES 10/29/2020
---	------	--

Comments: