

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

October 23, 2020

GOULD EVANS
4041 MILL STREET
KANSAS CITY, MO 64111

Permit No: PRCOM20203516
Project Title: LSR7 - LSN - 2020 ATHLETIC COMPLEX IMPROVEMENTS
Project Address: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086
Parcel Number: 52900043500000000
Location / Legal Description: LEES SUMMIT HIGH SCHOOL ON DOUGLAS STREET PT LOT 1 DAF: BEG NW COR SD LOT 1 TH S 87 DEG E 1485' MOL TH S 1 DEG W 1520' MOL TH N 87 DEG W 1494.41' TH N 1 DEG E 1032.45' TH N 1 DEG E 479.98' TO POB
Type of Work: ADDITION COMMERCIAL
Occupancy Group: ASSEMBLY FOR OUTDOOR ACTIVITIES INCL. STADIUMS, GRANDSTAND, AMUSEMENT PARKS
Description: RENOVATION TO EXISTING OUTDOOR STADIUM FACILITIES WHICH WILL INCLUDE EXPANSION OF EXISTING PRESS BOX; CONSTRUCTION OF NEW RESTROOMS, CONCESSIONS, AND TICKET BOOTHS; AND CONSTRUCTION OF NEW BLEACHER SEATING

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

2. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors. general contractor.

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

DEVELOPMENT SERVICES

1. (Action Required)

Add exterior emergency lighting outside of vestibule and stairwell from the press box.

2. 2018 IFC 506.1.2 Key boxes for non-standardized fire service elevator keys. Key boxes provided for non-standardized fire service elevator keys shall comply with Section 506.1 and 506.2 or as approved by the fire code official.

(Action Required)

Order a Knox Box for the elevator at knoxbox.com

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. The building permit for this project cannot be issued until the Development Services Department has received, approved, and processed the Final Development Plan.

Action required: Comment is for informational purposes.

2. 2018 IPC 403.1 Minimum number of fixtures. Plumbing fixtures shall be provided in the minimum number shown in Table 403.1, based on the actual use of the building or space. Uses not shown in Table 403.1 shall be considered individually by the code official. The number of occupants shall be determined by the International Building Code.

Action required: Insufficient number of fixtures provided. CMR has been submitted.

3. For the Health Department review contact Deb Sees with the Jackson County Public Works Department, Environmental Services Division, at (816) 847-7070. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

Action required: Comment is for informational purposes.

4. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

5. Prior to the installation or construction of any elevator equipment, an elevator equipment permit shall be obtained from the Missouri Department of Public Safety or its authorized representative.

Action required: Comment is for informational purposes.

6. Prior to the operation of any new elevator equipment or the issuance of the operating certificate, such elevator equipment shall be inspected by a licensed inspector. Testing must be performed in accordance with these rules and regulations. The testing must be witnessed by a licensed inspector.

Action required: Comment is for informational purposes.

7. Elevator Safety Act and Rules 701.361 - Each privately owned or operated installation and each installation owned or operated by the state of Missouri or any political subdivision of the state shall have a certificate of inspection and meet the safety code promulgated pursuant to sections 701.350 to 701.380.

DEVELOPMENT SERVICES

Action required: Comment is for informational purposes.

9. 2018 IBC 1209.2 Finish Materials. Walls, Floors and partitions in toilet and bathrooms shall comply with Sections 209.2.1 through 1209.2.4.

2018 1209.2.1 Floors and wall bases. In other than dwelling units, toilet, bathing and shower room floor finish materials shall have a smooth, hard, nonabsorbent surface. The intersections of such floors with walls shall have a smooth, hard, nonabsorbent vertical base that extends upward onto the walls not less than 4 inches.

2018 1209.2.2 Walls and partitions. Walls and partitions within 2 feet of service sinks, urinals and water closets shall have a smooth, hard, nonabsorbent surface, to a height of not less than 4 feet above the floor, and except for structural elements, the materials used in such walls shall be of a type that is not adversely affected by moisture. (See code section for possible exceptions.)

1209.2.3 Showers. (see code for details)

1209.2.4 Waterproof joints. (see code for details)

Action required: Modify drawings to show compliant wall finish materials at water closets and mop sink. If paint is used it must be epoxy based.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.