

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172519
Address: 237 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Morris	Failed	Friday, October 23, 2020

Corrective Action Required:

1	Misc	-must pass fire inspection before TCO will be issued -complete exterior facade -remove trash & construction debris -Tamper resistant Schrader valves at all condensing units -provide all condensing units -provide guard rails at retaining wall
---	------	--

Comments: