

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172538  
Address: 241 NW KESSLER DR, Unit:G, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Morris	Failed	Friday, October 23, 2020

Corrective Action Required:

1	Misc	-Anchor bolt required within 12 inches of plate ends. G3 -complete exterior trim work
---	------	--

**Comments:**