

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203385
Address: 818 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Passed	Sunday, October 25, 2020

Informational:
1 Misc - 1ST LAYER TYPE X BOTH SIDES 2 HR WALL -
- 2ND LAYER TYPE X BOTH SIDE 2 HR WALL -

Comments: