

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203385  
Address: 818 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Michael Harkins	Partial	Sunday, October 25, 2020

Corrective Action Required:

1	Misc	- MARK ALL FIRE RATED WALLS ABOVE ACCESSIBLE CEILINGS IN RED PAINTED STENCILING AS FOLLOWS ( 2HR FIRE AND / OR SMOKE BARRIER) PER PLAN REFERENCE NOTE 12 -
---	------	---

**Comments:**