

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200811

Address: 3521 SW MARKET ST, Unit:IR, LEES SUMMIT, MO 640823521 SW MARKET ST, LEES SUMMIT, MO  
64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Patrick Schonfeldt	Failed	Monday, October 26, 2020

Corrective Action Required:

1	Misc	INSPECTED PARTIAL IN WALL AT RETAIL, RESTROOMS - MAKE CRC LATERAL BRACING CONTINUOUS -COMPLETE ELECTRICAL -SECURE DWV 2" OR LESS -BLOCKING REQUIRED AT HARD LID CEILING LINE IN BATHROOMS - OK TO ONE SIDE ROCK PORTIONS INSPECTED
---	------	---

**Comments:**