

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172527
Address: 253 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Morris	Failed	Monday, October 26, 2020

Corrective Action Required:

1 Misc

- Fire department approval required
- Remove trash and construction debris
- Complete downspout installation
- unit 307 loose guardrail at balcony
- Horizontal grab bar in tub cannot exceed 36" AFF, ADA unit 105
- Install all exterior HVAC equipment with tamper resistant Schrader valves
- Complete the building facade
- Label main distribution panel

Comments: