

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202513
Address: 1527 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Patrick Schonfeldt	Failed	Monday, October 26, 2020

Corrective Action Required:

1	Misc	-ACTIVATE SMOKE DETECTORS, ENSURE SMOKE DETECTORS ARE INTERCONNECTED WITH SMOKE DETECTORS IN REST OF HOUSE
---	------	--

Comments: