

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191955
Address: 920 NE DEERBROOK ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Partial	Tuesday, October 27, 2020

Partial Correction:

1	Misc	-Protect plumbing per code. Install BOCA plate at bottom track for extra 2" of protection -Fb floor penetrations -Secure 2" or smaller pvc at mid-wall
---	------	--

Comments: