

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20201396  
Address: 1812 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:         | Outcome: | Date:                     |
|---|--------------------|----------|---------------------------|
| <b>All Rough Inspection - Residential</b> | Patrick Schonfeldt | Failed   | Tuesday, October 27, 2020 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -Seal all top and bottom penetrations throughout - 2nd floor<br>-seal all penetrations through air returns and plenums<br>-Complete all bath fan exhaust discharge<br>-Secure all DWV 2" or less at mid point<br>-complete gas fireplace installation per manufacturers instructions<br>-address notched dbl truss for DWV bedroom #2<br>-truss hangers per plans - 2nd floor<br>-terminate romex to boxes at basement stair landing ceiling<br>-Steel beam not fully inset in foundation pocket in basement - upset load bearing |
|---|------|---|

**Comments:**