

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193663  
Address: 1908 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Plot Plan Inspection</b>	John Morris	Failed	Tuesday, October 27, 2020

Corrective Action Required:

1	Misc	-5' sidewalk required per approved plot plan -locate and expose manhole in north rear yard corner as shown on plot plan -final grade per approved plot plan
---	------	---

**Comments:**