

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20201235
Address: 2935 SW ARBORWOOD DR, LEES SUMMIT, MO 64082
Inspected On: Tuesday, October 27, 2020
Inspected By: Patrick Schonfeldt
Expiration Date: 11/10/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Tuesday, October 27, 2020

Corrective Action Required:

1	Misc	-Complete final grade and sod - -Splash blocks at all downspout and sump pump discharge locations, minimum 36" distance from foundation
---	------	---

OK FOR TCO - EXPIRES 11/10/20