

Inspection Summary

Permit #: PRCOM20182609, Building Permit - Commercial

THE DONOVAN (SUMMIT SQUARE APARTMENTS PHASE II) - BUILDING #3

Address: 833 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Passed	Wednesday, October 28, 2020
Resolved			
1	OK TO COVER WHEN READY 5/8" MOLD-RESISTANT FIRECODE X GWB AT ELEVATOR SHAFT: 1ST LAYER 1-4, 2nd layer, ceiling 2nd;3rd,4th LOWER ELEVATOR ROOM- CEILING 1ST, 2ND, 3RD LAYER		
Underground Electrical Inspection - Commercial	Michael Harkins	Passed	Wednesday, October 28, 2020
Corrective Action Required			
1	- CONDUIT AT CORNER OF BUILDING TO CONDUIT UNDER SIDEWALK FOR LIGHTS -		
Occupancy Inspection - Planning	Hector Soto Jr.	Temporary C of O	Wednesday, October 28, 2020
Occupancy Inspection - Engineering	Joe Starlin	Passed	Wednesday, October 28, 2020
Informational			
1	Passed for final occupancy.		

Occupancy Inspection - Water Curtis Deason
Utilities

Passed

Wednesday,
October 28,
2020

Miscellaneous Inspection

Michael Harkins

Passed

Wednesday,
October 28,
2020

Resolved

1

Comments:
