



PHONE: (913) 764-6229 FAX: (913) 764-8198

BASEMENT WATERPROOFING----DRAINAGE----SUMP PUMPS----EROSION CONTROL

TO: Summit Homes
RE: Hawthorne Ridge; Lot #5
ADDRESS: 2922 SW Arboridge Dr. Lee's Summit, MO
PERMIT: #2020-1500
DATE: 10/28/2020

This letter is to document and verify our interior and exterior drain tile installation.

On July 7, 2020 on our work order # 426067 we installed:

- Damproofing spray on the exterior below grade portion of the foundation.
- Corrugated 4" sock drain tile on the exterior footing.
 - Connected under the footing to the sump pit.
- PVC drain tile to daylight.
- Covered the drain tile with 22 tons of your gravel.
- Sump pit in the front left corner, connected to the exterior drain tile.
- 3" corrugated inside drain tile.
 - Connected to the sump across the basement to the opposite, back right corner.

There were not any problems with this job, it was a normal installation for us.

On August 27, 2020 on our work order # 429795 we installed:

- Standard duty sump pump.
 - 1.5" ABS piping to drain to the exterior.
 - Drilled a single hole for pipe and cord, sealed sump pit lid.

There were no problems with the sump pump installation either.

Please let me know if there is any additional documentation I can provide.

Thank you,

Curtis Harris

Gordon Energy

curtish@gordonenergy.com