

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

October 28, 2020

SRKO LLC
24 NW CHIPMAN RD
LEES SUMMIT, MO 64086

Permit No: PRCOM20203968
Project Title: A STRONG STOP
Project Address: 1308 SW MARKET ST, LEES SUMMIT, MO 64081
Parcel Number: 61500037400000000
Location / Legal: REPLAT OF LOT 2, RESURVEY OF LOT 4 SIMONIN ADDITION TR-1
Description:
Type of Work: CHANGE OF TENANT
Occupancy Group: ASSEMBLY FOR INDOOR SPORTING INCL ARENAS, RINKS, COURTS, SWIMMING POOLS
Description: TENANT FINISH FOR PERSONAL TRAINING GYM - WORK INCLUDES RELOCATING A WALL, HVAC, AND ELECTRICAL TO MAKE RESTROOM ACCESSIBLE

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company name of licensed Plumbing Contractor.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

2. 2018 IPC 403.1 Minimum number of fixtures. Plumbing fixtures shall be provided in the minimum number shown in Table 403.1, based on the actual use of the building or space. Uses not shown in Table 403.1 shall be considered individually by the code official. The number of occupants shall be determined by the International Building Code.

DEVELOPMENT SERVICES

Action required: Provide mop sink and drinking fountain (or approved equivalent)

3. 2018 IPC 403.2 Separate Facilities. (As amended by Lee's Summit Code of Ordinances Section 7-405) Where plumbing fixtures are required, separate facilities shall be provided for each sex.

Exceptions:

1. Separate facilities shall not be required for dwelling units and sleeping units.
2. Separate facilities shall not be required in structures or tenant spaces with a total occupant load, including both employees and customers, of 15 or fewer.
3. Separate facilities shall not be required in mercantile occupancies in which the maximum occupant load is 100 or fewer.
4. Separate facilities shall not be required in business occupancies in which the maximum occupant load is 25 or fewer.

Action required: Comment is for informational purposes. Single restroom approved via CMR.

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent. (Verified At Inspection)

Post occupant load at 49.

2. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

Address front and back doors.

3. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Verified At Inspection)

Provide and mount one 2A10BC Fire Extinguisher.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.