

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20201088  
Address: 470 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                   | Inspector:      | Outcome: | Date:                      |
|-----------------------------------------------|-----------------|----------|----------------------------|
| <b>Final Building Inspection - Commercial</b> | Michael Harkins | Failed   | Thursday, October 29, 2020 |

Corrective Action Required:  
1 Misc - PAINT GAS LINES ON ROOF TO RTUs -

**Comments:**