

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200763  
Address: 2050 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Michael Harkins	Failed	Thursday, October 29, 2020

Informational:	
1 Misc	- BUILDING STEEL GROUNDING (3) STEEL COLUMNS CENTER OF BUILDING (1) EACH TENANT -
Corrective Action Required:	
2 Misc	- LAND ALL CONDUCTORS IN LUGS -

**Comments:**