

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202943
Address: 202 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Thursday, October 29, 2020

Corrective Action Required:

1	Misc	- PIPE WATER HEATER RELIEF VALVE TO FLOOR - - REPAIR/ REPLACE EXIT SIGN LIGHT -
---	------	--

Comments: