

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193693
Address: 420 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Thursday, October 29, 2020

Corrective Action Required:

1	Misc	: OK TO STOCK NO OCCUPANCY :
		<ul style="list-style-type: none">- PROVIDE BUBBLE COVERS EXTERIOR GFCIs -- INSULATE BATH SINK DRAINS -- BACKFLOW DEVICES SODA FOUNTAIN -- OPEN J BOX ROOF ACCESS ROOM ABOVE CEILING -- PAINT ROOFTOP GAS LINES -- PROVIDE GFCIs ROOF TOP UNITS -- LABEL RTUs AND DISCONNECTS -- PROVIDE COMBUSTION AIR FOR WATER HEATER -- HAND DRYER CLEARANCE WOMENS RESTROOM -- PROVIDE 67" TURNING RADIUS WOMEN'S RESTROOM -- ADDRESS CPTED CONDITIONS -

Comments: