

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200716
Address: 910 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Thursday, October 29, 2020

Corrective Action Required:

1	Misc	- PROVIDE HAMMER ARRESTORS WASHING MACHINE - - PROVIDE GFCI PROTECTION JANITORS CLOSET - - PIPE WATER HEATER RELIEF VALVE TO MOP SINK - - ADJUST SELF CLOSERS RESTROOM DOORS - - ADDRESS SURFACE MOUNTED HARDWARE ENTRY DOOR (SECTION 1010.9) - - PROVIDE SIGNAGE ENTRY DOOR (THIS DOOR TO REMAIN UNLOCKED DURING BUSINESS HOURS) -
---	------	--

Comments: