CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200763 Address: 2050 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--|----------|-----------------------------|
| Electrical Service Inspection - Commercial | Michael Harkins | Passed | Friday, October 30, 2020 |
| Informational: | | | |
| 1 Misc | - BUILDING STEEL GROUNDING (3) STEEL COLUMNS CENTER OF BUILDING (1) EACH TENANT - | | |

Comments: