

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20172527
Address: 253 NW KESSLER DR, LEES SUMMIT, MO 64081
Inspected On: Friday, October 30, 2020
Inspected By: John Morris
Expiration Date: 11/30/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Morris	Temporary C of O	Friday, October 30, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -Install all exterior HVAC equipment with tamper resistant Schrader valves
-Complete the building facade |
|---|------|---|