

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192520
Address: 704 SE OLDHAM CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Michael Harkins	Passed	Thursday, September 10, 2020

Informational:

1	Misc	-CONDUIT FROM TRANSFORMER TO POLE-WEST SIDE -TRANSFORMER TO CT CAB
---	------	---

Informational:

2	Misc	- 2ND CONDUIT FROM TRANSFORMER ON POLE NORTH SIDE AT HWY 50 TO CT CABINET @ REAR DOOR -
---	------	--

Informational:

3	Misc	- (4) DRIVEN GROUND RODS REAR DOOR AT METER CAN - - BUILDING STEEL STORAGE LOFT - - WATER ROOM 126 JANITOR CLOSET - - UFER IN FOOTING @ METER CAN -
---	------	--

Comments: