

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20193663
Address: 1908 SW RIVER RUN DR, LEES SUMMIT, MO 64082
Inspected On: Monday, November 02, 2020
Inspected By: John Morris
Expiration Date: 12/2/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Temporary C of O	Monday, November 02, 2020

Corrective Action Required:

1	Misc	-5' sidewalk required as shown on plot plan -Final grade per approved plot and sod -Downspouts and sump piping to discharge minimum 36 inches from foundation TCO valid through 12/02/2020
---	------	--