





ANALYTICAL REPORT

October 31, 2020

Work Order: 1J02670 Page 1 of 3

Report To

John Dimauro

City of Lee's Summit - Public Works Dept.

220 SE Green Str

Lees Summit, MO 64063

Project: Redford Construction

Project Number: Stoney Creek 4th Plat

Work	Order [Informa	tion
------	---------	---------	------

Date Received: 10/30/2020 9:45AM

Collector: Client

Phone: (816) 969-1200 PO Number: Routine Analysis

Analyte		Result	MRL	Batch	Method	Analyst Analyzed Qualifier
1J02670-01	Merrymann Tie In				Matrix:Drink Wtr	Collected: 10/30/20 08:25
Total Coliforms		<1.0 MPN/100ml	1.0	1DJ1361	9223B-QT	CLJ 10/30/20 16:30
E. Coli		<1.0 MPN/100ml	1.0	1DJ1361	9223B-QT	CLJ 10/30/20 16:30
1J02670-02	Georgetown Tie In				Matrix:Drink Wtr	Collected: 10/30/20 08:32
Total Coliforms		<1.0 MPN/100ml	1.0	1DJ1361	9223B-QT	CLJ 10/30/20 16:30
E. Coli		<1.0 MPN/100ml	1.0	1DJ1361	9223B-QT	CLJ 10/30/20 16:30
1J02670-03	Grindstone EOL				Matrix:Drink Wtr	Collected: 10/30/20 08:29
Total Coliforms		<1.0 MPN/100ml	1.0	1DJ1361	9223B-QT	CLJ 10/30/20 16:30
E. Coli		<1.0 MPN/100ml	1.0	1DJ1361	9223B-QT	CLJ 10/30/20 16:30
1J02670-04	Hightown EOL				Matrix:Drink Wtr	Collected: 10/30/20 08:35
Total Coliforms		<1.0 MPN/100ml	1.0	1DJ1361	9223B-QT	CLJ 10/30/20 16:30
E. Coli		<1.0 MPN/100ml	1.0	1DJ1361	9223B-QT	CLJ 10/30/20 16:30

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.







Page 2 of 3

City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

October 31, 2020 Work Order: 1J02670

Certified Analyses included in this Report

Method/Matrix	C Analyte	Analyte				
9223B-QT in Dr	ink Wtr					
	Total Coliforms	Total Coliforms				
	E. Coli		KS-KC,MO-KC			
Code	Description	Number	Expires			
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2021			
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2021			
MO-KC	Missouri Department of Natural Resources	140	04/30/2021			
SIA1X	Iowa Department of Natural Resources	95	02/01/2021			
SIAIX	iowa Department of Natural Resources	95	02/01/202			

End of Report

Keystone Laboratories, Inc.

Carolyn Jackson Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

6	6
P	Ŀ
E	-
	E
E	
-	4
	9
E	-
	å
6	
N	L
Ľ	
7	7
	ı
P	4
Ŀ	9
1	
þ	
h	
G	ı
4	-
U.	L
C)
CLIMIN OF COOLOD! RECORD	Š
2	4
7	U
	7
	9



600 E. 17th St. S Newton, IA. 50208 Phone:641-792-8451 Fax: 641-792-7989

3012 Ansborough Ave Waterloo, IA. 50701 Phone:319-235-4440 Fax:319-235-2480

835 South St Paul Street Kansas City, KS. 66105 Phone:913-321-7856 Fax:913-831-6778

PAGE: 1 of 1

	Relinguished by: (Signature)	celinquished by: (Signature)			Day 1	Day 1	Day 1	Day 1	OCICIAL OCIVIL EE #	CHENT SAMDLE #							PHONE:	CITY/ST/ZIP: Lee's	ADDRESS:	SITE NAME: Stoney		PRINT OR TYPE INFO BELOW:
	ature) Date				10/30/2020 8 35	10/30/2020 8:29	10/30/2020 8:32	10/30/2020 8:25		DATE								Summit, MO		Stoney Creek 4th Plat		D BELOW:
	225 Received to	7-30-20 Received by			HIGHTOWN EOL	GRINDSTONE EOL	GEORGETOWN TIE IN	MERRYMANN TIE IN	SAMPLE LUCATION							Email / FAX: JOHN.DIM/	PHONE: 816-977-5652	CITY/ST/ZIP: Lee's Sum	ADDRESS: 220 SE Green Street	CO. NAME: City of Lee's Summit	NAME: John DiMauro	REPORT TO:
Daniel (or Lab by, (orginature)	Sah by (Signature)	Received by: (Signature)			1 DW G X	1 DW G X	1 DW G X	1 DW G X	N G	OF IATE IRAE	RIX B/CC	MC	PC	DSIT	E	JOHN.DIMAURO@CITYOFLS.NET	652	Lee's Summit, MO, 64063	een Street	's Summit	uro	
Time:	272 272 - me	Date: (つ/か/とつ											-,-,-,-,-,-		ANALYSES REQUIRED		PHONE:		ADDRESS:	CO. NAME:	NAME:	BILL TO:
		Remarks:			40	63	02	NO	Sample Condition Sample #	8	Rush:	Sigil riold.		Wk Order #: /J02670	LAB USE ONLY		816-540-2030	Pleasant Hill, MO, 64080	17322 Rte 291	Redford Construction Co.	Daniel Salinas	