

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200905
Address: 2521 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Failed	Tuesday, November 03, 2020

Corrective Action Required:

1 Misc

- Still to verify fastening grid at rear elevation engineered wall project per plan 3/S505
- Provide gas piping pressure test
- Complete HVAC line set

OK TO ROCK

Comments: