CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20193581 Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 640812001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspectio | on: | Inspector: | Outcome: | Date: |
|--|---------|--|----------|-------------------------------|
| Detentio | n Basin | Ronald Paynter | Failed | Tuesday, November 03, 2020 |
| Informational: 1 Misc Informational: | | Ben's crew poured the floor for the end sections of lines B and D. RP 8-17-20 | | |
| 2 | Misc | Ben's crew formed up the wing walls for the end sections of lines B and D. RP 8-19-20 | | |
| Corrective Action Required: | | | | |
| 3 | Misc | Talked with Norm about the status of the detention basin not draining. They need to find and fix the issue. RP 11-3-20 | | |

Comments: