

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201668

Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082155 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Patrick Schonfeldt	Failed	Wednesday, November 04, 2020

Informational:

1	Misc	- INSPECTED IN WALL MC ON E, S, AND N WALLS ON E SIDE OF BUILDING. OK TO COVER PORTION INSPECTED
---	------	--

Corrective Action Required:

2	Misc	- 11/4 - INSPECTED LOWER IN WALL MC ON N WALL REMAINING, E SIDE TENANT, SECURE MC WITHIN 10" OF PENETRATION, ADD BOX TO LIGHT FIXTURE AND PUT MC IN BOX
---	------	---

Comments: