

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193157
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Curb - Proof Roll	Joe Starlin	Passed	Thursday, November 05, 2020

Informational:

1 Misc

6-15-20 3:06pm We are proof rolling at the East side of the building for curb. The proof roll passed. CFS was on site for it and agreed. 6-18-20 ESS, CFS and my self performed a second proof roll at the building on the east side. They had made some corrections. It has passed at this time and is subject for another proof roll if it rains. Rain is forecasted and they have been made aware.

11-4-20 Steve did the proof roll on the north side and it passed. I did the west side and it passed.

Comments: