

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192644
Address: 2924 NW AUDUBON LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Failed	Monday, October 19, 2020

Corrective Action Required:

1 Misc

- Only partial approval of sidewalk on record
- All unpaid fees must be paid in full
- Sod
- Downspouts to discharge minimum 36 inches from foundation

Comments: