

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20192644  
Address: 2924 NW AUDUBON LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Ronald Paynter	Passed	Thursday, November 05, 2020

Informational:	
1        Misc	10-6-20 7:51am The forms are set and the aggregate is compacted. The contractor knows to stay ADA compliant.

Corrective Action Required:	
2        Misc	Forms were placed and aggregate was present and compacted. Needs to adjust forms, close to out of compliance. No picture framing sidewalks any more, brush finish only. Must use white cure. RP 10-12-20

Informational:	
3        Misc	Not sure why an inspection was called in on a completed sidewalk? RP 11-4-20

**Comments:**